

Item #	Building	Floor Tiles (& mastic)	Above Ceiling Fire Proofing	Mudded Pipe Fittings	Ceiling Tiles	Pipe Insulation
1	49. Computer Center - Constructed 1973					
2	Ground Floor	Yes	Yes	PACM	No	PACM
3	First Floor	Yes	Yes	PACM	No	PACM
4	Second Floor	Yes	Yes	PACM	No	PACM
5	Third Floor	Yes	Yes	PACM	No	PACM

Mechanical Rooms	Gasket Material	Window Caulking	Transite	Dry Wall Compound	Crawl Space	Fire Doors
N/A	PACM	PACM	N/A	PACM	N/A	Yes
N/A	PACM	PACM	N/A	PACM	N/A	Yes
N/A	PACM	PACM	N/A	PACM	N/A	Yes
Abated	PACM	PACM	N/A	PACM	N/A	Yes